

OFFICE OF THE MUNICIPAL COUNCIL GAJWEL - PRAGNAPUR
SIDDIPET DIST



No.F1/129/2025

Date: 18 / 02 / 2025

SANITARY CERTIFICATE

This is to certify that there is No Objection to run the St. Mary,s Vidyaneketan High School at H.No 10-67/1/A Pragnapur ,X,Road, , Gajwel -pragnapur. Siddipet District. The Management provided the sufficient sanitary facilities in and around the School premises. Hence there is No Objection for running the School on Sanitary point of view with the following conditions.


Following conditions must be followed:


1. Subject to condition of structural soundness certificate.
2. NOC from Fire Department.
3. Sufficient number of toilets for boys and girls should be provided separately.
4. Premises should be kept clean & pollution free.
5. If any health related issues raised to the students of this School in future time the Sanitary Certificate will be cancelled automatically without any notice.
6. The generated waste shall be divided into wet, dry & domestic hazardous and give to the municipal vehicles.
7. The Management will not allow single use plastic (SUP) in the school Premises.
8. The Management will abide by the Solid Waste Management (SWM) Rules -2016.
9. They should equip all kinds of fire instruments to prevent fire accidents in the premises.
10. Strictly Follow the COVID-19 Rules.
11. Renewal of Sanitary Certificate every Financial year from this Municipality is Mandatory.

Commissioner

Municipal Council

Gajwel – Pragnapur.


18/02/25


18/02/25

GOVERNMENT OF TELANGANA
OFFICE OF THE DY.EXECUTIVE ENGINEER MB-INTRA SUB-DIVISION
GAJWEL.

From,
A.Praveen Kumar B.E.,
Dy.Executive Engineer,
MB(Intra),Sub-Division Gajwel.

To,
The Principal,
St.Mary's Vidyaniketan High
School ,Pregnapur-Gajwel,
Siddipet District.

Lr.No. Lab/Water Test Report/St.Mary's Vidyaniketan High School/2025,
Dt:15.02.2025

Sir,


Sub:- MB-Intra – Sub-Division Gajwel –Submission of Water Quality Test Report of water samples from St.Mary's Vidyaniketan High School, Pregnapur-Gajwel– Reg.

Ref : Letter Dated.05-02-2025 of the Principal, St.Mary's Vidyaniketan High School, Pregnapur-Gajwel, Siddipet District.

Anent to the reference to subject cited above, I am here with submitting the Water quality test report of Water samples collected from Borewell located in St.Mary's Vidyaniketan High School, Pregnapur-Gajwel.Reports are suggested that water is chemically satisfied and bacteriologically wholesome.

Yours faithfully,

Encl:Lab Report


15/2/25
Dy.Executive Engineer,
MB(Intra), SD-Gajwel.
Dy.Executive Engineer,
MB-Intra, SD-Gajwel.

OFFICE OF THE DEPUTY EXECUTIVE ENGINEER
MB SUB DIVISION – GAJWEL DIST SIDDIPET
DRINKING WATER TESTING LAB-KOMATIBANDA

Date: 07/02/2025

Location: St Marys High school Pragnapur

Chemical Examination of Sample Water

Sl .no	Parameter	Bore water Result	Desirable Limit	Permissible Limit
1	PH	7.00	6.5 – 8.5	No relaxation
2	Alkalinity	444 Mg/liter	200 Mg/liter	600 Mg/liter
3	Chlorides	184 Mg/liter	250 Mg/liter	1000 Mg/liter
4	Hardness	600 Mg/liter	300 Mg/liter	600 Mg/liter
5	Fluoride	1.30 Mg/liter	1.0 Mg/liter	1.5 Mg/liter
6	Iron	0 Mg/liter	0.3 Mg/liter	1.0 Mg/liter
7	Sulphate	60 Mg/liter	200 Mg/liter	400 Mg/liter
8	Nitrate	4 Mg/liter	45 Mg/liter	No relaxation
9	TDS	696 Mg/liter	500 Mg/liter	2000 Mg/liter


RESULT: Chemically satisfied.

Bacteriological Examination of Sample Water

Sl No	Type of source	Name of the Location	MPN of Coliforms/100ml	MPN of E.Coli/100ml
1.	Bore water	St Marys High school	0	Nil

RESULT: Bacteriologically wholesome


CHEMIST


MICROBIOLOGIST


Dy. Executive Engine
MB-Intra, SD-Gajwel.